



An ISO 9001:2015 Company

MSME
सूक्ष्म, लघु एवं मध्यम उद्यम
MICRO, SMALL & MEDIUM ENTERPRISES

Certified Company

02527-27403 9922676184 vijayenterprises1415@gmail.com



VIJAY
ENTERPRISES
NISHAN ENTERPRISES-SINCE 2011

Certificate No: VE/CERT/26-27/085

30.05.2026

Certificate No: VE/CERT/26-27/117

24.06.2026

REFILLING CERTIFICATE

TO WHOM SO IT MAY CONCERN

This is to certify that the following Fire Extinguishers have been New Supply as per

IS: 2190 for

CLIENT NAME: P.S. DESHMUKH MEMORIAL ACADEMY (CBSE)

TAL-SHAHAPUR, DIST-THANE

Fire Extinguishers details:

Sr. No	Type of Ext.	Capacity	Qty.	Refilling Date	Refilling Due Date	Remarks
1	ABC type Fire Extinguisher	5 kg	6 Nos.	02.06.2026	01.06.2028	OK
2	Co2 type Extinguisher	3 kg	5 No	24.06.2026	23.06.2028	OK

For VIJAY ENTERPRISES

Authorized Signatory

PRINCIPAL

P.S. DESHMUKH MEMORIAL ACADEMY
C.B.S.E. (PATTERN)
SHAHAPUR - 421 601 (THANE)

CHAIRMAN

Executive Committee
Shahapur Taluka Education
Society, Shahapur (Taluka)

FIRE EXTINGUISHERS HYDRANT SYSTEM SERVICES & MAINTENANCE FIRE PROJECT FIRE & SAFETY SIGNAGE
House No 166/1, Gaonkar Compound, Asangaon, 421301, Taluka Shahapur, District-Thane, Maharashtra, India

GUARANTEE TO YOUR SAFETY



शहापूर तालुका एज्युकेशन सोसायटी

शहापूर, जि. ठाणे पिन-४२१ ६०१

☎ : ९५२५२७ - २७२०३८ / २७३२२२

* कार्यकारी मंडळ *

* विश्वस्त मंडळ *

* अध्यक्ष *

* सचिव *

* अध्यक्ष *

* सचिव *

जयवंत पां. देशमुख

विद्या श. वेखंडे

सदाशिव द. खाडे

विश्वनाथ अ. शेणॉय

जा. क्र. STEC/

/

दिनांक :

/

/२०

Declaration Regarding Fire Safety Certificate

This is to certify and declare that Shahapur Taluka Education Society's P. S. Deshmukh Memorial Academy, having CBSE Affiliation No. 1130421, has initiated the process for Final Fire Safety Certificate with the concerned Government Fire Department.

The School Management has duly submitted an application to the concerned Fire Department for the renewal and issuance of the Final Fire Safety Certificate. In connection with the said application, the school has been issued a Provisional No Objection Certificate (NOC) by the competent Fire Department.

The School Management undertakes to obtain the Final Fire Safety Certificate from the competent Fire Safety Authority upon completion of the prescribed process and, immediately thereafter, to update/upload the valid certificate on the CBSE SARAS Portal and maintain the same as part of the school's statutory safety and compliance records.

The School Management further confirms that the matter is under process with the concerned competent authority and that the school shall comply with the applicable CBSE affiliation and school safety requirements relating to Fire Safety.

This declaration is submitted for CBSE SARAS record, documentation and compliance purposes.

CHAIRMAN
Executive Committee
Shahapur Taluka Education
Society, Shahapur (Thane)

PRINCIPAL
P.S. DESHMUKH MEMORIAL ACADEMY
C.B.S.E. (PATTERN)
SHAHAPUR - 421 601 (THANE).



अंबरनाथ नगरपरिषद , अंबरनाथ

No. MFS/ 18/AMC/2026-27

DATE : 23/07/2026

To,
M/S, P. S. DESHMUKH MEMORIAL
ACADEMY C.B.S.E SECTION
Village- Shahapur , Tal- Shahapur
Dist- Thane

Sub: NOC stipulating fire protection and fire fighting requirements
for your old Existing Ground + 3 School Building on land
bearing CTS. No. 364 Village – Shahapur, Tal- Shahapur, Dist-
Thane.

- Ref: 1) Application from P. S. DESHMUKH MEMORIAL ACADEMY
dated on 07/07/2026
2) Application from A. S & Associate (Arch) dated on
29/05/2026
3) 2 Set of approved drawing by an architect
4) Gampachayt Shahapur C.C Dated on 1098/25/01/1990
4) Delegation For power office Order no MFS /2025/1109
2025/1109 dated no 16/07/2025.

This is a proposal for provisional fire NOC for your old Ground + 3
School building on CTS.No. 364 Village – Shahapur, Tal- Shahapur, Dist-
Thane.

Total Plot area is 1004.00 Sq.mts and proposed built up
area is 1221.75 Sq. mts. Height of the building is 13.18 Mtrs. The detail of
the proposed Construction is as under,

School Building :

Sr. No.	Floor	Built Up Area in Sq.
01	Ground Floor	336.08
02	1 st floor	308.45
03	2 nd Floor	308.45
04	3 rd Floor	265.77
Total Built up Area in Sq. Mtrs		1221.75

CHAIRMAN
Executive Committee
Shahapur Taluka Education
Society, Shahapur (T. & T.)

PRINCIPAL
P.S. DESHMUKH MEMORIAL ACADEMY
C.B.S.E. (PATTERN)
SHAHAPUR - 421 601 (THANE).

This NOC is Valid Subject to fulfillment of the following conditions:
Provisions of Maharashtra Fire Prevention and Life Safety
Measures Act, 2006

1. Under **Section 3** of "Maharashtra Fire Prevention and Life Safety
Measures Act, 2006" (hereinafter referred to as "said Act"). The applicant
(developer, owner, occupier by whatever name called) shall comply with all

the Fire and Life Safety measures adhering to National Building Code of India, 2016 and as amended from time to time failing which it shall be treated as a violation of the said Act.

2. As per the provision as under :- 10 of the said Act. No person other than the License Agency shall carry out the work of providing Fire Prevention and Life Safety Measures or performing such other related activities required to be carried out in any place or building or part thereof provided that,
 - A) If the Fire Officer is satisfied that, for any reason, to be recorded in writing, the owner or occupier is not able to carry out the fire prevention and fire safety measures in any such place or building or part thereof through a Licensed Agency, he may authorize any person or persons he thinks fit to carry out such work, and any work carried out by such authorized person or persons shall be deemed to be carried out by a Licensed Agency.
 - B) No Licensed Agency or any other person claiming to be such Licensed Agency shall give a certificate under sub-section (3) of section 3 regarding the compliance of the fire prevention and life safety measures or maintenance thereof in good repair and efficient condition, without there being actual such compliance or maintenance. The names of the License Agencies approved by Directorate of Maharashtra is available on our website www.mahafireservice.gov.in
3. Though certain conditions are stipulated from the said Act and the National Building Code of India, it is obligatory on part of the applicant that is developer, builder, occupier, owner, tenant, by what so ever named called to abide with the provisions of the said Act failing which it shall be actionable under the provisions of said act.
4. The plans of the building should be approved by The Concern Competent Authority.
5. The Occupancy certificate should be obtained from The Competent Authority. The O.C. shall be issued subject to "Final No-Objection Certificate" from this Department.
6. Proper roads in the premises should be provided & marked on ground for easy mobility of the Fire Brigade Appliance as per the guidelines given in NBC-2016, should be kept free from obstructions all the time. The load bearing capacity of internal roads must be minimum 45Tones. The width of the road shall not be less than 6.0 Mtrs for easy maneuver of the fire engine. However, the marginal open space shall be seen in to by the concern competent authority of the building proposal department.
7. Inspection of Fire Fighting installation will be carryout by the representative of this Fire department during instaliation of the Fire fighting system.
8. All portable fire fighting equipments installed at various locations as per local hazard such as Co2-DCP, Foam, Fire buckets should be strictly confirming to relevant IS specification. All the fire fighting equipments shall be well maintained and should be easily accessible in case of emergency. The monitoring mechanism for all Fire Fighting equipment should be designed and implemented. The Guidelines should be followed based on IS 15683 & IS- 2190 – Code of Practice for selection, Installation and Maintenance of Portable First-Aid Fire Extinguishers.
9. All the fire fighting equipments shall be well maintained and should be easily accessible in case of emergency.
10. Emergency Telephone numbers like "Police", "Fire Brigade", "Hospital", "Doctors", and "Responsible persons of the company" should be displayed in security cabin & production building.
11. It shall be ensured that security staff & every employee of the co. are trained in handling fire fighting equipments & fire fighting.
12. "Fire Extinguisher", "Fire Bucket" "Danger" "No Smoking" caution boards should be displayed at the places physically shown & the caution

CHAIRMAN

Executive Committee
Shahapur Taluka Education
Society, Shahapur (Thane)

PRINCIPAL

P.S. DESHMUKH MEMORIAL ACADEMY
C.B.S.E. (PATTERN)
SHAHAPUR - 421 601 (THANE).

boards should be easily visible and as per the guidelines given in IS:9457, IS:12349 and IS:12407.

13. The house keeping shall be well maintained within the entire building area.
14. All electrical appliances/ fittings and fixture should be strictly flame proof.
15. The Fire Exit Drill or Evacuation Drill should be plan and instruction should be given to the society.
16. On Site & Off site emergency plan/ Evacuation Plan Shall be prepared Mock drills shall be conducted twice a year & instruction to every employee shall be given once in three months.
17. In future if the developer intends to go for expansion, alteration, modification of the building an approval of fire department must be obtained before commencing proposed construction.
18. Stability certificate to the buildings shall be obtained from Architect or competent person as per the Rule 3-A of Maharashtra Factories Rules, 1963.
19. The height & other clearances / approvals must be obtained from local Civil Aviation Department if necessary.
20. All necessary approvals required from Government / Planning / Special Planning Authority shall be obtained, as applicable.

Requirement and Provision: - The following active fire protection system will be required for the safety of the building

Sr. No.	FIRE FIGHTING INSTALLATION	Requirements	Provision	Remarks
1.	Portable Fire Extinguishers	Required	IS: 15683 & 2190	All floors, Meter Room, Class room, Ptc
2.	Hose Reel	Required at prominent places.	Stair cases of the building	On each floor in the Staircase landing for Fire Fighting. The first aid hose reel shall be connected directly to riser/down comer main and diameter of the hose reel shall not be less than 19mm confirming to IS 884:1985
3.	Down Comer	Required	In Staircase of the Buildings	Required to provide in the Staircase and Fire Escape Staircase. Landing of Valve should be installed confirming to IS:5290.
4.	Manually Operated Fire Alarm System	Required	At Various strategic location	MOEFA system also includes talk-back system and PASystem; it should be connected to alternate power supply.

CHAIRMAN

Executive Committee
Shahapur Taluka Education
Society, Shahapur (Thane)



PRINCIPAL

P.S. DESHMUKH MEMORIAL ACADEMY
C.B.S.E. (PATTERN)
SHAHAPUR - 421 601 (THANE).

5.	Yard Hydrant or Ring Hydrant Around the building	Required	At Various Strategic Locations.	Fire Brigade Inlet Connection should be provided. Hydrant points should be provided with 2 Nos. of Delivery Hose confirming to IS -14933 -2001 along with standard Branch (Universal) confirming to IS 2871. The distance between 2 Hydrants should not be more Than 45 mtrs. The Guideline should be followed per IS 3844:1989
6.	Fire brigade connection	Required at the main gate		
7.	Terrace Tank	Required 25,000 ltr.	On Terrace of building	
8.	Booster pump	Required	On Terrace Level near Fire Tank 900 Lpm	
09.	Automatic Smoke Detection System	Required for admin building and meter room	Automatic Smoke Detection System should be provided standards and guidelines given In Is -11360 -1985 Specification for Smoke Detection for use Automatic Electrical fire Alarm System. <u>Detection System for Cable Trench Should be Provided.</u> Heat Detectors Should be provided for Canteen Area as per the Standards and guidelines given IS 2175 1988 Specification for Heat Sensitive fire Detectors For Use in Automatic Fire Alarm System.	
10.	Auto Backup	Required	Required at all fire safety systems.	
11.	Emergency lights	Required	Required at prominent places.	
12.	Sign Indicators for all fire safety, safe evacuation of occupants in case of emergency signs	Required Prominent Places.	Sign indicators should provided at prominent places as per the guidelines given in IS:9457 for Safety color and Safety IS:12349 for Fire Protection Safety Signs IS:12407 for Graphics symbols for Fire Protection Plan.	

CHAIRMAN
Executive Committee
Shahapur Taluka Education
Society, Shahapur (Thane)



PRINCIPAL
P.S. DESHMUKH MEMORIAL ACADEMY
C.B.S.E. (PATTERN)
SHAHAPUR - 421 601 (THANE).

NOTE : Fix fire fighting installations such as risers. Hydrant connections. Hose reels etc. Shall be provided in separate shaft having opening at floor with Glass Cabinet having locking arrangement to avoid theft and damage.

ALTERNATE SOURCE OF POWER SUPPLY: An alternate source of LV/HV supply from a separate substation or from a diesel generator with appropriate changeover over switch shall be provided for fire pumps, booster pump, sprinkler pump, jockey pump, staircase and corridor lighting circuits and fire alarm system, detection system, public address system, voice evacuation system etc. It shall be housed in separate cabin.

Access :

Two entrance gates each of width not less than 04.50 Mtr and height clearance not less than 6.00 Mtrs shall be provided,

Courtyards. :

1. The Courtyards on all sided of the building shall be paved suitably to Bear the load of the fire engines weighing up to 45 m tones and shall be flushed to road level.
2. The courtyards shall be in one plane.

PORTABLE FIRE EXTINGUISHERS :

- a) Two dry Chemical Power (A.B.C) Type fire extinguisher of 6 Kgs. Capacity having I.S.S Certification mark and two buckets filled with dry, clean sand shall be kept in Electric meter room as well as lift Machine Room.
- b) Eight Dry Chemical Powder (A.B.C) type fire extinguishers each of 6 Kgs. Capacity having I.S.I Certification mark shall be kept at parking area equally distributed prominent places in stills.

TERRACE DOOR :

- a) The Top Half Portion of the doors shall be provided with louvers.
- b) The latch – Lock shall be installed from the terrace side at the height of not more than 1 mtrs.
- c) The glass front of 6 inch diameter with the breakable glass shall be provided just above the latch lock so as to open the latch in case of an emergency by breaking the glass.

In addition to the above, all provision under the National Building Code of India-2016 shall be strictly adhered, also if any change in activity or Proposed expansion or Subletting of Plot, NOC from this department is essential

This is a “Provisional No-Objection Certificate”. After compliance with above mentioned recommendations / conditions, inspection of the fire prevention & protection systems provided by you will be carried out by this department & after satisfactory performance of the system “Final No-Objection Certificate” will be issued.

As per Maharashtra Fire Prevention and Life Safety Measures Act, 2006, Section 25 - Annexure- Part III, M/S P. S. DESHMUKH MEMORIAL ACADEMY C.B.S,E SECTION has paid Fire Protection Fund Fees amounting to Rs 1,62,249/- (one Lac Sixty Two Thousand Two hundred Forty nine only)vide UTR No.TDCBH2620100034 dated on .20/7/2026

Fire Officer
Ambarath Municipal Council
(Nominated officer by MFS
Govt. of Maharashtra)



Copy to:
Director, Directorate of Maharashtra Fire Service

CHAIRMAN
Executive Committee
Shahapur Taluka Educational
Society, Shahapur (Thane)

PRINCIPAL
P.S. DESHMUKH MEMORIAL ACADEMY
C.B.S.E. (PATTERN)
SHAHAPUR - 421 601 (THANE),